

# TOMS RIVER MUNICIPAL UTILITIES AUTHORITY

## **YOU MUST PASS BOTH INSPECTIONS BEFORE YOU CAN APPLY FOR YOUR CERTIFICATE OF OCCUPANCY**

*The TRMUA Field Operations Office shall receive notification 72 hours in advance of all reconnect and cut/ cap excavations. When the cut & cap/ reconnect is complete and visible (prior to 1:30 pm) the contractor will contact the Field Operations Office for the inspection. All final inspections will occur within 72 hours (inclusive of business days) of notification.*

*For inspections, please call the Field Operations Department at 732-240-3500 x116*

## RECONNECT INSPECTIONS

### 1. **INITIAL** Inspection:

At curb clean-out, excavation is to be open and dry so the Inspector can see how the connection (or re-connection) was done. When reconnecting from curb cleanout back to TRMUA side of the lateral, a **FERNCO- STRONG BACK RC SERIES REPAIR COUPLING** or **TRANSITION COUPLING** must be used. A triangulation must also be provided to TRMUA at this time, drawn on T.R.M.U.A. form. If this is new construction, the measurements are to be taken off the structure (front outside corners of house to this connection). Excavation is to be open, dry and 6" of  $\frac{3}{4}$ " clean stone must be in place under the re-connect.

#### NOTE:

**\*Clean-out must be 4" long-turn tee-wye or 4" wye + street 45.**

**\*YOU MUST USE SCH 40 PVC OR CLASS 52 DUCTILE IRON PIPE**

**\*\*\*CONTRACTOR MUST PASS TV INSPECTION AT TIME OF RECONNECT\*\*\***

(FERNCO- FLEXIBLE COUPLINGS WILL NOT BE PERMITTED)

DRY = DEWATERED WITH A 6" DEPTH OF  $\frac{3}{4}$ " CLEAN STONE BEDDING

†Excavations shall comply with the Underground Facility Protection Act (NJSA 48:2-73) & the One-Call Damage Prevention System (NJAC 14-2)

### 2. **FINAL** Inspection:

Curb cleanouts shall be set to grade and properly protected with an MUA-approved cover appliance (CC-4 Box-Geneco), and shall remain accessible, without obstructions.

The letter "H" shall be chiseled on top of the concrete curb at the cleanout location.

**\*MUST HAVE A 4" PVC CLEAN-OUT PLUG**